




# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name: No-Burn® Plus**

Product Sample Information		Certificate Information	
Manufacturer:	No-Burn, Inc.	Certificate No:	120521-01
Manf. Website:	www.noburn.com	Certified By:	
CSI Category & No.:	Intumescent Painting (09 96 46)		Raja S. Tannous, Laboratory Director
Date Produced:	4/3/2012	Date:	May 21, 2012

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.1, 2010 (Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>	
	Criterion	Compliant?	Criterion	Compliant?
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.1-2010)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*).

### Potential Applications

- ANSI/ASHRAE/USGBC/IES Standard 189.1-2009, 8.4.2.2: Paints & Coatings
- USGBC LEED for Schools, 2009, IEQ Credit 4.2: LEM - Paints & Coatings
- Collaborative for High Performance Schools (CHPS) rating system, 2009 Criteria EQ2.2.2: Paints & Coatings
- Green Guide for Healthcare, V2.2, 2007, EQ Credit 4.2: LEM - Wall & Ceiling Finishes
- ANSI/GBI 01-2010 Green Building Assessment Protocol, 2010, Table 12.2.1-B: Walls

**Narrative:** No-Burn, Inc. selected a sample representative of its No-Burn® Plus product and submitted it for testing commencing on 5/1/2012. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.1-2010. The results of the test are presented in Berkeley Analytical report, 578-001-02A-May2112.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.


**Disclaimer:** This Certificate of Compliance affirms that: 1) the product sample was tested according to the referenced standard; 2) the measured VOC emissions were evaluated for the defined exposure scenario(s); and 3) the results meet the acceptance criteria of the referenced standard(s). Potential applications of the test and this certificate are suggested. Berkeley Analytical provides this Certificate of Compliance "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.



# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name: No-Burn® Plus XD**

Product Sample Information		Certificate Information	
Manufacturer:	No-Burn, Inc.	Certificate No:	120516-04
Manf. Website:	www.noburn.com	Certified By:	
CSI Category & No.:	Intumescent Painting (09 96 46)		Raja S. Tannous, Laboratory Director
Date Produced:	4/10/2012	Date:	May 16, 2012

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.1, 2010 (Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>	
	Criterion	Compliant?	Criterion	Compliant?
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.1-2010)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*).

### Potential Applications

- ANSI/ASHRAE/USGBC/IES Standard 189.1-2009, 8.4.2.2: Paints & Coatings
- USGBC LEED for Schools, 2009, IEQ Credit 4.2: LEM - Paints & Coatings
- Collaborative for High Performance Schools (CHPS) rating system, 2009 Criteria EQ2.2.2: Paints & Coatings
- Green Guide for Healthcare, V2.2, 2007, EQ Credit 4.2: LEM - Wall & Ceiling Finishes
- ANSI/GBI 01-2010 Green Building Assessment Protocol, 2010, Table 12.2.1-B: Walls

**Narrative:** No-Burn, Inc. selected a sample representative of its No-Burn® Plus XD product and submitted it for testing commencing on 4/25/2012. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.1-2010. The results of the test are presented in Berkeley Analytical report, 578-001-01A-May1612.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.


**Disclaimer:** This Certificate of Compliance affirms that: 1) the product sample was tested according to the referenced standard; 2) the measured VOC emissions were evaluated for the defined exposure scenario(s); and 3) the results meet the acceptance criteria of the referenced standard(s). Potential applications of the test and this certificate are suggested. Berkeley Analytical provides this Certificate of Compliance "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.



# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name: No-Burn® Plus ThB**

Product Sample Information		Certificate Information	
Company:	No-Burn, Inc.	Certificate No:	170901-01
Company Website:	www.noburn.com	Certified By:	 Raja S. Tannous, Laboratory Director
Product Type:	Paints & Coatings	Date:	September 1, 2017
Date Produced:	6/1/2017		

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>		TVOC <sup>4</sup>
	Criterion	Compliant?	Criterion	Compliant?	
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	> 0.5 - 4.9 mg/m <sup>3</sup>
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	> 0.5 - 4.9 mg/m <sup>3</sup>

**Product Coverage<sup>5</sup>:** 596 g/m<sup>2</sup>

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m<sup>3</sup>, >0.5 – 4.9 mg/m<sup>3</sup>, and ≥5.0 mg/m<sup>3</sup>
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

### Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4, BD&C, ID&C
- The WELL Building Standard
- ANSI/GBI 01, Green Building Assessment Protocol
- ANSI/ASHRAE/USGBC/IES Standard 189.1

**Narrative:** No-Burn, Inc. selected a sample representative of its No-Burn® Plus ThB intumescent coating product and submitted it on 8/8/2017 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 578-002-01A-Sep0117.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

**DISCLAIMER:** THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.