



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	2280-2014:0100
<b>CATEGORY:</b>	2280 - COATING MATERIALS (FLAME SPREAD)
<b>LISTEE:</b>	NO BURN INC. 1392 High Street, Suite 211, Wadsworth, OH, 44281 Contact: Campbell, Kelly (330) 336-5800 Email: kelly@noburn.com
<b>DESIGN:</b>	Type No Burn Plus "NB Plus 8 mils wet over OSB" coating material. The No Burn material is sprayed on the surface of the oriented strand board (OSB) with thickness of 8 mils.
<b>RATING:</b>	Class A  Flame Spread: 5  Smoke Developed Index: 35
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, product label and Intertek label.
<b>APPROVAL:</b>	Listed as a coating material for application to OSB surfaces to reduce flame spread. Approval limited to interior wall/ceiling surfaces when the coatings are applied at the rates specified in accordance with the manufacturer's installation instructions. Authority having jurisdiction should be consulted prior to installation.
<b>NOTES:</b>	

11-09-10 bh



results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/15/2022**

**Listing Expires: 06/30/2023**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division